

Fire Sprinkler Save

Blaine, MN

Sprinkler save we had just Sunday morning. Box of combustibles too close to the water heater. Occupant discovered the fire and then pulled the box away from the water heater and it flared up at which point the sprinkler head in the hall activated and extinguished the fire. The sprinkler in the utility room was a 200 degree head and the one in the hall was 155 degrees so it activated first. This was a 5 unit row townhome. Original call came in as a woman yelling hysterically that there was a fire in the lower level.

